

Pasco County Utilities Emergency Rule Notification

Installation Name: **Wesley Center Wastewater Treatment Facility**

Installation Address : **7501 Boyette Road, Wesley Chapel, FL 33545**

For further information, contact James Hircock, Environmental Compliance Specialist,
727-457-0358 (Cell) or 727-247-0391 (PTT)

Permit Number (if applicable): **FLA016094**

Date and time of the incident or discovery: **DATE: 17 October 2017 TIME: 0945**

Location of the incident or discovery : **4720 Mapletree Lp, Wesley Chapel, FL**

Suspected source and cause of incident or discovery : **While performing routine maintenance on TR-436-ARV-1 and discovered the ARV leaking**

Type of pollution, including substance or contaminant name(s): **Untreated domestic waste.**

Estimate amount of pollution, including substance or contaminant name(s): **Approximately 100 gallons of untreated domestic waste (15 gallons of sludge recovered). Used 300 gallons water to clean and neutralize the site**

Source: (e.g. land, water, air) affected: **LAND: WATER: AIR:**

potentially affected areas beyond installation property boundary: **NONE**

Potential risk (public health, safety, or welfare): **High Medium Low None**

Identification of other parties notified of incident and time notification occurred :

Name: **(FDEP) Ileana Hernandez** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Daniel Biles, P.E.)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Douglas Tobin)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Flip Mellinger)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Mike Moore–BOCC Chairman)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(ALL Directors) Rob Marin** Time Notified: **(24 Hour) (48 Hour)**

Additional information that may be helpful: **MAP # 436 SSO # 869, W.O. # 596684, corrected flapper seal and placed back into service. NO further action.**