

# Pasco County Utilities Emergency Rule Notification

- Installation Name: **Southeast Wastewater Treatment Facility**
- Installation Address: **6039 Handcart Road, Zephyrhills, FL 33544**
- For further information, contact James Hircock, Environmental Compliance Specialist,  
727-457-0358 (Cell) or 813-247-0391 (PTT)
- Permit Number (if applicable): **FLA012737**
- Date and time of the incident or discovery: **DATE: 26 October 2017 TIME: 8:30 AM**
- Location of the incident or discovery: **37750 Chancey Road**
- Suspected source and cause of incident or discovery: **P/S # 4-629 pumps were blocked with debris causing overflow.**
- Type of pollution, including substance or contaminant name(s): **Untreated domestic waste.**
- Estimate amount of pollution, including substance or contaminant name(s): **Approximately 2000 gallons of untreated domestic waste (1500 gallons recovered). Cleaned area using water and lime.**
- Source: (e.g. land, water, air) affected: **LAND:   X   WATER: \_\_\_\_\_ AIR: \_\_\_\_\_**
- potentially affected areas beyond installation property boundary: **NONE**
- Potential risk (public health, safety, or welfare): **High    Medium    Low    None   X**
- Identification of other parties notified of incident and time notification occurred:
  - Name: **(FDEP) Ileana Hernandez** Time Notified: **(24 Hour) X (48 Hour)**
  - Name: **(Daniel Biles, P.E.)** Time Notified: **(24 Hour) (48 Hour)**
  - Name: **(Tambrey Laine)** Time Notified: **(24 Hour) (48 Hour)**
  - Name: **(Flip Mellinger)** Time Notified: **(24 Hour) (48 Hour)**
  - Name: **(Mike Moore–BOCC Chairman)** Time Notified: **(24 Hour) (48 Hour)**
  - Name: **(ALL Directors) Rob Marin** Time Notified: **(24 Hour) X (48 Hour)**
- Additional information that may be helpful: **MAP # 629, W/O # 597458, SSO # 874**