

## Pasco County Utilities Emergency Rule Notification

- Installation Name: **Shady Hills Wastewater Treatment Facility**
- Installation Address: **14220 Hays Road, Spring Hill, FL 34610**
- For further information, contact James Hircock, Environmental Compliance Specialist,  
813-235-6189 ext. 6905 or 727-247-0391 (Cell)
- Permit Number (if applicable): **FLA012741**
- Date and time of the incident or discovery: **DATE: 18 October 2018 TIME: 14:20 PM**
- Location of the incident or discovery: **14220 Hays Road, Shady Hills WWTP**
- Suspected source and cause of incident or discovery: **Aeration Basin # 5 was being placed on line when the flange on the new IR piping started leaking and caused the spill.**
- Type of pollution, including substance or contaminant name(s): **Treated domestic waste.**
- Estimate amount of pollution, including substance or contaminant name(s): **Approximately 400 gallons of treated domestic waste (0 gallons recovered).**
- Source: (e.g. land, water, air) affected: **LAND: X WATER: \_\_\_\_\_ AIR: \_\_\_\_\_**
- potentially affected areas beyond installation property boundary: **NONE**
- Potential risk (public health, safety, or welfare): **High \_\_\_\_\_ Medium \_\_\_\_\_ Low \_\_\_\_\_ None X**
- Identification of other parties notified of incident and time notification occurred:
  - Name: (FDEP) Ileana Hernandez Time Notified: (24 Hour) X (48 Hour)**
  - Name: (Daniel Biles, P.E.) Time Notified: (24 Hour) (48 Hour)**
  - Name: (Tambrey Laine) Time Notified: (24 Hour) (48 Hour)**
  - Name: (Michael Carballa) Time Notified: (24 Hour) (48 Hour)**
  - Name: (Mike Wells-BOCC Chairman) Time Notified: (24 Hour) (48 Hour)**
  - Name: (ALL Directors) Rob Marin Time Notified: (24 Hour) X (48 Hour)**
- Additional information that may be helpful: **MAP # 209, WO # 655972, SSO # 948. The bolts on the flange were tightened by PCL Construction. NO further action needed.**