

Pasco County Utilities Emergency Rule Notification

- Installation Name: **Land O Lakes Wastewater Treatment Facility**
- Installation Address: **6101 Parkway Blvd, Land O Lakes, FL 34639**
- For further information, contact James Hircock, Environmental Compliance Specialist,
813-235-6189 ext. 6905 or 727-247-0391 (Cell)
- Permit Number (if applicable): **FLA012731**
- Date and time of the incident or discovery: **DATE: 24 October 2018 TIME: 11:45 AM**
- Location of the incident or discovery: **Pristine Lake Boulevard and Amelia Rose Way**
- Suspected source and cause of incident or discovery: **Contractor bored through 6" Force Main (F/M) located in the asphalt of Pristine Lakes Blvd.**
- Type of pollution, including substance or contaminant name(s): **Untreated domestic waste.**
- Estimate amount of pollution, including substance or contaminant name(s): **Approximately 5,000 gallons of untreated domestic waste (16,500 gallons recovered from storm culvert). Used 100 pounds lime and 1,500 gallons water to neutralize area.**
- Source: (e.g. land, water, air) affected: **LAND: X WATER: _____ AIR: _____**
- potentially affected areas beyond installation property boundary: **NONE**
- Potential risk (public health, safety, or welfare): **High _____ Medium _____ Low _____ None X**
- Identification of other parties notified of incident and time notification occurred:
 - Name: **(FDEP) Ileana Hernandez** Time Notified: **(24 Hour) X (48 Hour)**
 - Name: **(Daniel Biles, P.E.)** Time Notified: **(24 Hour) (48 Hour)**
 - Name: **(Tambrey Laine)** Time Notified: **(24 Hour) (48 Hour)**
 - Name: **(Michael Carballa)** Time Notified: **(24 Hour) (48 Hour)**
 - Name: **(Mike Wells-BOCC Chairman)** Time Notified: **(24 Hour) (48 Hour)**
 - Name: **(ALL Directors) Rob Marin** Time Notified: **(24 Hour) X (48 Hour)**
- Additional information that may be helpful: **MAP # 326, SSO # 950, WO # 656507. Utilities was onsite doing locates when notified of hit. Repaired 6" F/M and re-activated system NO further action needed.**