

## Pasco County Utilities Emergency Rule Notification

- Installation Name: **Shady Hills Wastewater Treatment Facility**
- Installation Address: **14220 Hays Road, Spring Hill, FL 34610**
- For further information, contact James Hircock, Environmental Compliance Specialist,  
813-235-6189 ext. 6905 or 727-247-0391 (Cell)
- Permit Number (if applicable): **FLA012741**
- Date and time of the incident or discovery: **DATE: 11 December 2018 TIME: 1:30 PM**
- Location of the incident or discovery: **8700 Little Road, New Port Richey**
- Suspected source and cause of incident or discovery: **Contractor drill crew broke 2" F/M and caused the spill.**
- Type of pollution, including substance or contaminant name(s): **Untreated domestic waste.**
- Estimate amount of pollution, including substance or contaminant name(s): **Approximately 300 gallons of untreated domestic waste (900 gallons recovered – retrieved from storm ditch). Used 10 pounds of lime and clean water to neutralize site.**
- Source: (e.g. land, water, air) affected: **LAND: X WATER: \_\_\_\_\_ AIR: \_\_\_\_\_**
- potentially affected areas beyond installation property boundary: **NONE**
- Potential risk (public health, safety, or welfare): **High \_\_\_ Medium \_\_\_ Low \_\_\_ None X**
- Identification of other parties notified of incident and time notification occurred:
  - Name: **(FDEP) Ileana Hernandez** Time Notified: **(24 Hour) X (48 Hour)**
  - Name: **(Daniel Biles, P.E.)** Time Notified: **(24 Hour) (48 Hour)**
  - Name: **(Tambrey Laine)** Time Notified: **(24 Hour) (48 Hour)**
  - Name: **(Michael Carballa)** Time Notified: **(24 Hour) (48 Hour)**
  - Name: **(Ronald E. Oakley–BOCC Chairman)** Time Notified: **(24 Hour) (48 Hour)**
  - Name: **(ALL Directors) Rob Marin** Time Notified: **(24 Hour) X (48 Hour)**
- Additional information that may be helpful: **MAP # 90, WO # 663313, SSO # 958. Repaired 2" Iron body valve and a 6" SS nipple with a compression Coupler. NO further action.**