

## Pasco County Utilities Emergency Rule Notification

- Installation Name: Land O Lakes Wastewater Treatment Facility
- Installation Address: 6101 Parkway Blvd, Land O Lakes, FL 34639
- For further information, contact James Hircock, Environmental Compliance Specialist,  
813-235-6189 ext. 6905 or 727-247-0391 (Cell)
- Permit Number (if applicable): FLA012731
- Date and time of the incident or discovery: DATE: 20 December 2018 TIME: 8:30 AM
- Location of the incident or discovery: Land O'Lakes WWTP CCC
- Suspected source and cause of incident or discovery: Heavy rain storm caused CCC high service pumps not to keep up with high effluent demand.
- Type of pollution, including substance or contaminant name(s): treated domestic waste.
- Estimate amount of pollution, including substance or contaminant name(s): Approximately 5,760 gallons of treated domestic waste (0 gallons recovered).
- Source: (e.g. land, water, air) affected: LAND: X WATER: \_\_\_\_\_ AIR: \_\_\_\_\_
- potentially affected areas beyond installation property boundary: NONE
- Potential risk (public health, safety, or welfare): High \_\_\_ Medium \_\_\_ Low \_\_\_ None X
- Identification of other parties notified of incident and time notification occurred:
  - Name: (FDEP) Ileana Hernandez Time Notified: (24 Hour) X (48 Hour)
  - Name: (Daniel Biles, P.E.) Time Notified: (24 Hour) (48 Hour)
  - Name: (Tambrey Laine) Time Notified: (24 Hour) (48 Hour)
  - Name: (Michael Carballa) Time Notified: (24 Hour) (48 Hour)
  - Name: (Ronald E. Oakley-BOCC Chairman) Time Notified: (24 Hour) (48 Hour)
  - Name: (ALL Directors) Rob Marin Time Notified: (24 Hour) X (48 Hour)
- Additional information that may be helpful: MAP # 150, SSO # 960. Spill lasted 2 hours and flowed to plant storm water pond adjacent to the CCC. Samples taken.