

Pasco County Utilities Emergency Rule Notification

- Installation Name: **Embassy Hills Wastewater Treatment Facility**
- Installation Address: **9512 Crabtree Lane, Port Richey, FL 34668**
- For further information, contact James Hircock, Environmental Compliance Specialist,
813-235-6189 ext. 6905 or 727-247-0391 (Cell)
- Permit Number (if applicable): **FLA012735**
- Date and time of the incident or discovery: **DATE: 22 February 2019 TIME: 8:45 PM**
- Location of the incident or discovery: **10031 Cherry Creek Lane, Port Richey**
- Suspected source and cause of incident or discovery: **A broken ARV that rusted coming off a 20" Force Main caused the spill.**
- Type of pollution, including substance or contaminant name(s): **Untreated domestic waste.**
- Estimate amount of pollution, including substance or contaminant name(s): **Approximately 33,750 gallons of untreated domestic waste (6,000 gallons recovered). Used water and 125 lbs. of lime to neutralize the site.**
- Source: (e.g. land, water, air) affected: **LAND: X WATER: X AIR: _____**
- potentially affected areas beyond installation property boundary: **Retention Canal North of Fox Hollow Dr. and Palm Ave.**
- Potential risk (public health, safety, or welfare): **High _____ Medium _____ Low _____ None X**
- Identification of other parties notified of incident and time notification occurred:
 - Name: (FDEP) Ileana Hernandez Time Notified: (24 Hour) X (48 Hour)**
 - Name: (Daniel Biles, P.E.) Time Notified: (24 Hour) (48 Hour)**
 - Name: (Tambrey Laine) Time Notified: (24 Hour) (48 Hour)**
 - Name: (Michael Carballa, P.E., BCEE) Time Notified: (24 Hour) (48 Hour)**
 - Name: (Ronald E. Oakley–BOCC Chairman) Time Notified: (24 Hour) (48 Hour)**
 - Name: (ALL Directors) Rob Marin Time Notified: (24 Hour) X (48 Hour)**
- Additional information that may be helpful: **MAP # 69, SSO # 967, W.O. # 674056. Will be rehabilitating the ARV attached to the 20" force main. Samples will be pulled from retention canal.**