

Pasco County Utilities Emergency Rule Notification

- Installation Name: Land O Lakes Wastewater Treatment Facility
- Installation Address: 6101 Parkway Blvd, Land O Lakes, FL 34639
- For further information, contact James Hircock, Environmental Compliance Specialist,
813-235-6189 ext. 6905 or 727-247-0391 (Cell)
- Permit Number (if applicable): FLA012731
- Date and time of the incident or discovery: **DATE: 14 March 2019 TIME: 8:00 PM**
- Location of the incident or discovery: 17001 Lixberry Way Bexley Subdivision
- Suspected source and cause of incident or discovery: **Valve #3 on Map 256, was identified as a line valve, which was incorrect and inadvertently opened due to a problem at LS- 5-256. The valve was a stub out and due to main line pressure caused the cap to leak.**
- Type of pollution, including substance or contaminant name(s): Untreated domestic waste.
- Estimate amount of pollution, including substance or contaminant name(s): **Approximately 800 gallons of untreated domestic waste (1,500 gallons recovered). Used 100 pounds lime and 1,500 gallons clean water to neutralize and restore site.**
- Source: (e.g. land, water, air) affected: **LAND: X WATER: _____ AIR: _____**
- potentially affected areas beyond installation property boundary: **NONE**
- Potential risk (public health, safety, or welfare): **High _____ Medium _____ Low _____ None X**
- Identification of other parties notified of incident and time notification occurred:
 - Name: (FDEP) Ileana Hernandez Time Notified: (24 Hour) X (48 Hour)
 - Name: (Daniel Biles, P.E.) Time Notified: (24 Hour) (48 Hour)
 - Name: (Tambrey Laine) Time Notified: (24 Hour) (48 Hour)
 - Name: (Michael Carballa) Time Notified: (24 Hour) (48 Hour)
 - Name: (Ronald E. Oakley-BOCC Chairman) Time Notified: (24 Hour) (48 Hour)
 - Name: (ALL Directors) Rob Marin Time Notified: (24 Hour) X (48 Hour)
- Additional information that may be helpful: **MAP # 256, SSO # 969, WO # 676059. NO Further action needed.**