

Pasco County Utilities Emergency Rule Notification

- Installation Name: **Shady Hills Wastewater Treatment Facility**
- Installation Address: **14220 Hays Road, Spring Hill, FL 34610**
- For further information, contact James Hircock, Environmental Compliance Specialist,
813-235-6189 ext. 6905 or 727-247-0391 (Cell)
- Permit Number (if applicable): **FLA012741**
- Date and time of the incident or discovery: **DATE: 20 April 2019 TIME: 10:20 AM**
- Location of the incident or discovery: **14220 Hays Road (Shady Hills WWTP)**
- Suspected source and cause of incident or discovery: **Ras Pump # 5 love joy broke, blankets climbed and caused the spill. Unable to stop flow to Clarifier #1 due to contractor work at the splitter box, davit removed.**
- Type of pollution, including substance or contaminant name(s): **Untreated domestic waste.**
- Estimate amount of pollution, including substance or contaminant name(s): **Approximately 300,000 gallons of untreated domestic waste (0 gallons recovered) material was mostly clear waste and not sludge.**
- Source: (e.g. land, water, air) affected: **LAND: X WATER: _____ AIR: _____**
- potentially affected areas beyond installation property boundary: **NONE**
- Potential risk (public health, safety, or welfare): **High Medium Low None X**
- Identification of other parties notified of incident and time notification occurred:
 - Name: **(FDEP) Ileana Hernandez** Time Notified: **(24 Hour) X (48 Hour)**
 - Name: **(Daniel Biles, P.E.)** Time Notified: **(24 Hour) (48 Hour)**
 - Name: **(Tambrey Laine)** Time Notified: **(24 Hour) (48 Hour)**
 - Name: **(Michael Carballa)** Time Notified: **(24 Hour) (48 Hour)**
 - Name: **(Ronald E. Oakley-BOCC Chairman)** Time Notified: **(24 Hour) (48 Hour)**
 - Name: **(ALL Directors) Rob Marin** Time Notified: **(24 Hour) X (48 Hour)**
- Additional information that may be helpful: **MAP # 209, SSO # 972. Repaired mechanical issue with pump. NO further action.**