

Pasco County Utilities Emergency Rule Notification

- Installation Name: **Southeast Wastewater Treatment Facility**
- Installation Address: **6039 Handcart Road, Zephyrhills, FL 33544**
- For further information, contact James Hircock, Environmental Compliance Specialist,
727-457-0358 (Cell) or 813-247-0391 (PTT)
- Permit Number (if applicable): **FLA012737**
- Date and time of the incident or discovery: **DATE: 7 May 2019 TIME: 10:55 AM**
- Location of the incident or discovery: **Meadow Pointe Blvd. & State Road 54**
- Suspected source and cause of incident or discovery: **TR-508-ARV-1 air release valve was leaking**
- Type of pollution, including substance or contaminant name(s): **Untreated domestic waste.**
- Estimate amount of pollution, including substance or contaminant name(s): **Approximately 250 gallons of untreated domestic waste (200 gallons recovered). Used 100 pounds lime and water to neutralize and restore site.**
- Source: (e.g. land, water, air) affected: **LAND: X WATER: AIR:**
- potentially affected areas beyond installation property boundary: **NONE**
- Potential risk (public health, safety, or welfare): **High Medium Low None X**
- Identification of other parties notified of incident and time notification occurred:
 - Name: (FDEP) Ileana Hernandez Time Notified: (24 Hour) X (48 Hour)**
 - Name: (Daniel Biles, P.E.) Time Notified: (24 Hour) (48 Hour)**
 - Name: (Tambrey Laine) Time Notified: (24 Hour) (48 Hour)**
 - Name: (Michael Carballa, P.E., BCEE) Time Notified: (24 Hour) (48 Hour)**
 - Name: (Ronald E. Oakley-BOCC Chairman) Time Notified: (24 Hour) (48 Hour)**
 - Name: (ALL Directors) Rob Marin Time Notified: (24 Hour) X (48 Hour)**
- Additional information that may be helpful: **MAP # 508, W/O # 683411, SSO # 973. changed out the leaking air release valve.**