

Pasco County Utilities Emergency Rule Notification

- Installation Name: Land O Lakes Wastewater Treatment Facility
- Installation Address: 6101 Parkway Blvd, Land O Lakes, FL 34639
- For further information, contact James Hircock, Environmental Compliance Specialist,
813-235-6189 ext. 6905 or 727-247-0391 (Cell)
- Permit Number (if applicable): FLA012731
- Date and time of the incident or discovery: DATE: 5 June 2019 TIME: 2:15 PM
- Location of the incident or discovery: Lake Thomas Road and Drexel Road
- Suspected source and cause of incident or discovery: Motor Vehicle hit and damaged ARV.
- Type of pollution, including substance or contaminant name(s): Untreated domestic waste.
- Estimate amount of pollution, including substance or contaminant name(s): Approximately 1,500 gallons of untreated domestic waste (1,500 gallons recovered).
- Source: (e.g. land, water, air) affected: LAND: X WATER: _____ AIR: _____
- potentially affected areas beyond installation property boundary: NONE. Spread 20 pounds lime and 1,000 gallons clean water to neutralize the impacted area.
- Potential risk (public health, safety, or welfare): High ___ Medium ___ Low ___ None X
- Identification of other parties notified of incident and time notification occurred:
 - Name: (FDEP) Ileana Hernandez Time Notified: (24 Hour) X (48 Hour)
 - Name: (Daniel Biles, P.E.) Time Notified: (24 Hour) (48 Hour)
 - Name: (Tambrey Laine) Time Notified: (24 Hour) (48 Hour)
 - Name: (Michael Carballa) Time Notified: (24 Hour) (48 Hour)
 - Name: (Ronald E. Oakley-BOCC Chairman) Time Notified: (24 Hour) (48 Hour)
 - Name: (Rob Marin - Utilities Director) Time Notified: (24 Hour) X (48 Hour)
 - Name: (ALL Directors) Jason Mickel Time Notified: (24 Hour) X (48 Hour)
- Additional information that may be helpful: MAP # 309, SSO # 975, WO # 688759. Isolated 2" ball valve under ARV and replaced.