

Pasco County Utilities Emergency Rule Notification

- Installation Name: **Wesley Center Wastewater Treatment Facility**
- Installation Address: **7501 Boyette Road, Wesley Chapel, FL 33544**
- For further information, contact James Hircock, Environmental Compliance Specialist,
727-247-0391 (Cell) or 813-235-6189 ext. 6905
- Permit Number (if applicable): **FLA016094**
- Date and time of the incident or discovery: **DATE: 14 June 2019 TIME: 3:00 PM**
- Location of the incident or discovery: **SR 54 and US 41**
- Suspected source and cause of incident or discovery: **Failed ARV.**
- Type of pollution, including substance or contaminant name(s): **Untreated Domestic Waste**
- Estimate amount of pollution, including substance or contaminant name(s): **Approximately 12,000 Gallons of Untreated Domestic Waste (26,400 Gallons recovered).**
- Source: (e.g. land, water, air) affected: **LAND: X WATER: _____ AIR: _____**
- potentially affected areas beyond installation property boundary: **NONE, Spread lime and water to neutralize the impacted area.**
- Potential risk (public health, safety, or welfare): **High _____ Medium _____ Low _____ None X**
- Identification of other parties notified of incident and time notification occurred:
 - Name: (FDEP) Ileana Hernandez Time Notified: (24 Hour) X (48 Hour)**
 - Name: (Daniel Biles, P.E.) Time Notified: (24 Hour) (48 Hour)**
 - Name: (Tambrey Laine) Time Notified: (24 Hour) (48 Hour)**
 - Name: (Michael Carballa, P.E., BCEE) Time Notified: (24 Hour) (48 Hour)**
 - Name: (Ronald E. Oakley-BOCC Chairman) Time Notified: (24 Hour) (48 Hour)**
 - Name: (Rob Marin - Utilities Director) Time Notified: (24 Hour) X (48 Hour)**
 - Name: (ALL Directors) Jason Mickel Time Notified: (24 Hour) X (48 Hour)**
- Additional information that may be helpful: **MAP # 330, SSO # 977, W.O. # 689859. Fecal samples taken from receiving storm water retention pond on East side of US 41 of SR 54.**