

Pasco County Utilities Emergency Rule Notification

- Installation Name: Wesley Center Wastewater Treatment Facility
- Installation Address: 7501 Boyette Road, Wesley Chapel, FL 33544
- For further information, contact James Hircock, Environmental Compliance Specialist,
727-247-0391 (Cell) or 813-235-6189 ext. 6905
- Permit Number (if applicable): FLA016094
- Date and time of the incident or discovery: DATE: 17 June 2019 TIME: 9:30 PM
- Location of the incident or discovery: PS 1-419 Ancient Oaks Blvd.
- Suspected source and cause of incident or discovery: Wet well blanket needed cleaning and caused the pinch valve float not to tilt properly causing the pinch valve not to operate properly.
- Type of pollution, including substance or contaminant name(s): Untreated Domestic Waste
- Estimate amount of pollution, including substance or contaminant name(s): Approximately 103,440 Gallons of Untreated Domestic Waste (0 Gallons recovered).
- Source: (e.g. land, water, air) affected: LAND: X WATER: AIR:
- potentially affected areas beyond installation property boundary: NONE, Spread 160 pounds lime and water to neutralize the impacted area.
- Potential risk (public health, safety, or welfare): High Medium Low None X
- Identification of other parties notified of incident and time notification occurred
- Name: (FDEP) Ileana Hernandez Time Notified: (24 Hour) X (48 Hour)
- Name: (Daniel Biles, P.E.) Time Notified: (24 Hour) (48 Hour)
- Name: (Tambrey Laine) Time Notified: (24 Hour) (48 Hour)
- Name: (Michael Carballa, P.E., BCEE) Time Notified: (24 Hour) (48 Hour)
- Name: (Ronald E. Oakley-BOCC Chairman) Time Notified: (24 Hour) (48 Hour)
- Name: (Rob Marin - Utilities Director) Time Notified: (24 Hour) X (48 Hour)
- Name: (ALL Directors) Jason Mickel Time Notified: (24 Hour) X (48 Hour)
- Additional information that may be helpful: MAP # 419, W.O, # 690088 SSO # 978. NO further action needed.