

Pasco County Utilities Emergency Rule Notification

- Installation Name: **Shady Hills Wastewater Treatment Facility**
- Installation Address: **14220 Hays Road, Spring Hill, FL 34610**
- For further information, contact James Hircock, Environmental Compliance Specialist,
813-235-6189 ext. 6905 or 727-247-0391 (Cell)
- Permit Number (if applicable): **FLA012741**
- Date and time of the incident or discovery: **DATE: 18 June 2019 TIME: 6:30 AM**
- Location of the incident or discovery: **12540 Clock Tower Pkwy - Hudson (MPS 8-67)**
- Suspected source and cause of incident or discovery: **Station lost power and had to transfer manually to generator power because terminal strip for the float was bad causing the spill.**
- Type of pollution, including substance or contaminant name(s): **Untreated domestic waste.**
- Estimate amount of pollution, including substance or contaminant name(s): **Approximately 500 gallons of untreated domestic waste (700 gallons recovered).**
- Source: (e.g. land, water, air) affected: **LAND: X WATER: _____ AIR: _____**
- potentially affected areas beyond installation property boundary: **NONE. Spread 20 pounds lime and water to neutralize the impacted area.**
- Potential risk (public health, safety, or welfare): **High ___ Medium ___ Low ___ None X**
- Identification of other parties notified of incident and time notification occurred:
 - Name: **(FDEP) Rose Taylor** Time Notified: **(24 Hour) X (48 Hour)**
 - Name: **(Daniel Biles, P.E.)** Time Notified: **(24 Hour) (48 Hour)**
 - Name: **(Tambrey Laine)** Time Notified: **(24 Hour) (48 Hour)**
 - Name: **(Michael Carballa, P.E., BCEE)** Time Notified: **(24 Hour) (48 Hour)**
 - Name: **(Ronald E. Oakley-BOCC Chairman)** Time Notified: **(24 Hour) (48 Hour)**
 - Name: **(Rob Marin - Utilities Director)** Time Notified: **(24 Hour) X (48 Hour)**
 - Name: **(ALL Directors) Jason Mickel** Time Notified: **(24 Hour) X (48 Hour)**
- Additional information that may be helpful: **MAP # 67, WO # 690103, SSO # 979. Terminal Strip replaced and panel box checked for other issues. NO further action.**