

# Pasco County Utilities Emergency Rule Notification

---

- Installation Name: **New Port Richey Wastewater Treatment Facility**
- Installation Address: **4730 Main Street, New Port Richey, FL 34654**
- For further information, contact Meghan Harbaugh, Environmental Compliance Specialist: 813-929-2755 ext.6904 or 727-992-5983 (Cell)
- Permit Number (if applicable): **FL0127434**
- Date and time of the incident or discovery: **DATE: 14 August 2021 TIME: 8:20 PM**
- Location of the incident or discovery: **4802 Drift Tide Dr., New Port Richey**
- Suspected source and cause of incident or discovery: **Vehicle struck and damaged ARV, causing the spill.**
- Type of pollution, including substance or contaminant name(s): **Untreated domestic waste.**
- Estimate amount of pollution, including substance or contaminant name(s): **Approximately 100 gallons of untreated domestic waste (0 gallons recovered). Rainwater washed in area and applied lime to neutralize the site.**
- Source: (e.g. land, water, air) affected: **LAND: X WATER: \_\_\_\_\_ AIR: \_\_\_\_\_**
- Potentially affected areas beyond installation property boundary: **NONE.**
- Potential risk (public health, safety, or welfare): **High     Medium     Low     None X**
- Identification of other parties notified of incident and time notification occurred:

Name: **(FDEP) Brianna Godwin** Time Notified: **(24 Hour) X (48 Hour)**

Name: **(Daniel Biles, P.E.)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Tambrey Laine)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Michael Carballa)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Ronald E. Oakley–BOCC Chairman)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Rob Marin - Utilities Director)** Time Notified: **(24 Hour) X (48 Hour)**

Name: **(ALL Directors) Jason Mickel** Time Notified: **(24 Hour) X (48 Hour)**

- Additional information that may be helpful: **MAP # 27, SSO # 1134, WO # 909885.**