

Pasco County Utilities Emergency Rule Notification

- Installation Name: **Southeast Wastewater Treatment Facility**
- Installation Address: **6039 Handcart Road, Zephyrhills, FL 33544**
- For further information, contact Meghan Harbaugh, Environmental Compliance Specialist: 813-929-2755 ext. 6904 or 727-992-5983 (Cell)
- Permit Number (if applicable): **FLA012737**
- Date and time of the incident or discovery: **DATE: 18 May 2022 TIME: 11:25 AM**
- Location of the incident or discovery: **Intersection of River Glen Blvd. and Major Oak Dr., Wesley Chapel**
- Suspected source and cause of incident or discovery: **Debris clogged ARV, resulting in release**
- Type of pollution, including substance or contaminant name(s): **Untreated domestic waste.**
- Estimate amount of pollution, including substance or contaminant name(s): **Approximately 250 gallons of untreated domestic waste (50 gallons recovered). Used lime and fresh water to neutralize and restore site.**
- Source: (e.g. land, water, air) affected: **LAND: X WATER: AIR:**
- Potentially affected areas beyond installation property boundary: **NONE**
- Potential risk (public health, safety, or welfare): **High Medium Low None X**
- Identification of other parties notified of incident and time notification occurred:

Name: **(FDEP) Avion Stevenson** Time Notified: **(24 Hour) X (48 Hour)**

Name: **(Daniel Biles, P.E.)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Tambrey Laine)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Michael Carballa, P.E., BCEE)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Kathryn Starkey–BOCC Chairman)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(ALL Directors) Jason Mickel** Time Notified: **(24 Hour) X (48 Hour)**

- Additional information that may be helpful: **MAP #543, W/O #951098, SSO #1174. ARV replaced and brought back into service. No waterways were impacted and there is no risk to public health.**