

Pasco County Utilities Emergency Rule Notification

- Installation Name: **Wesley Center Wastewater Treatment Facility**
- Installation Address: **7501 Boyette Road, Wesley Chapel, FL 33544**
- For further information, contact Meghan Harbaugh, Environmental Compliance Specialist: 813-929-2755 ext. 6904 or 727-992-5983 (Cell)
- Permit Number (if applicable): **FLA016094**
- Date and time of the incident or discovery: **DATE: 20 May 2022 TIME: 3:11 PM**
- Location of the incident or discovery: **9028 McKendree Rd., Wesley Chapel**
- Suspected source and cause of incident or discovery: **Break in 12" force main pipe**
- Type of pollution, including substance or contaminant name(s): **Untreated Domestic Waste**
- Estimate amount of pollution, including substance or contaminant name(s): **6,048 gallons of untreated domestic waste (3,000 gallons recovered). Used water and lime to neutralize the affected area.**
- Source: (e.g. land, water, air) affected: **LAND: X WATER: _____ AIR: _____**
- Potentially affected areas beyond installation property boundary: **NONE**
- Potential risk (public health, safety, or welfare): **High Medium Low None X**
- Identification of other parties notified of incident and time notification occurred:

Name: **(FDEP) Avion Stevenson** Time Notified: **(24 Hour) (48 Hour) X**

Name: **(Daniel Biles, P.E.)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Tambrey Laine)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Michael Carballa, P.E., BCEE)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Kathryn Starkey–BOCC Chairman)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(ALL Directors) Jason Mickel** Time Notified: **(24 Hour) (48 Hour) X**

- Additional information that may be helpful: **MAP #467, SSO #1175, WO #951520. No waterways were affected and there is no risk to public health. State Watch Office, Public Notice of Pollution, and FDOH have been notified. Requesting that CIP project to replace section of force main is expedited.**