

# Pasco County Utilities Emergency Rule Notification

---

- Installation Name: **Wesley Center Wastewater Treatment Facility**
- Installation Address: **7501 Boyette Road, Wesley Chapel, FL 33544**
- For further information, contact Meghan Harbaugh, Environmental Compliance Specialist: 813-929-2755 ext. 6904 or 727-992-5983 (Cell)
- Permit Number (if applicable): **FLA016094**
- Date and time of the incident or discovery: **DATE: 03 June 2022 TIME: 3:00 PM**
- Location of the incident or discovery: **5324 C.R. 581, Wesley Chapel**
- Suspected source and cause of incident or discovery: **Vehicle struck ARV**
- Type of pollution, including substance or contaminant name(s): **Untreated Domestic Waste**
- Estimate amount of pollution, including substance or contaminant name(s): **150 gallons of untreated domestic waste (0 gallons recovered). Used water and lime to neutralize the affected area.**
- Source: (e.g. land, water, air) affected: **LAND:  X  WATER: \_\_\_\_\_ AIR: \_\_\_\_\_**
- Potentially affected areas beyond installation property boundary: **NONE**
- Potential risk (public health, safety, or welfare): **High   Medium   Low   None  X**
- Identification of other parties notified of incident and time notification occurred:

Name: **(FDEP) Avion Stevenson** Time Notified: **(24 Hour) X (48 Hour)**

Name: **(Daniel Biles, P.E.)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Tambrey Laine)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Michael Carballa, P.E., BCEE)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Kathryn Starkey–BOCC Chairman)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(ALL Directors) Jason Mickel** Time Notified: **(24 Hour) X (48 Hour)**

- Additional information that may be helpful: **MAP #453, SSO #1177. ARV was repaired and yellow bollards were reinstalled. No waterways were affected and there is no risk to public health.**